



ETL Listed
File #2001066



EQUIPMENT SPECIFICATIONS

To be Model BDH wall mounted, pass over exhaust hood complying with NFPA-96, bearing ETL Sanitation Listing as manufactured by Discount Restaurant Hoods, Inc.

Item to be (L) _____ long x 30" deep x 36" high in _____ section(s) as per drawing. Unit(s) constructed of 18 gauge stainless steel where exposed with external seams and joints welded liquid tight. All exposed surfaces are to be polished to the #4 finish.

Unit(s) to have U.L. classified aluminum baffle grease extractors, mounted in stainless steel frame with removable stainless steel grease cup and trough.

3" Back air space comes standard.

Listed one exhaust duct opening (minimum) for exhaust hoods up to 16 Ft. in length. Listed at minimum 260 CFM per linear foot.

Exhaust Hood to have following options:

- _____ Stainless steel baffle grease extractors.
- _____ 3" side air space. Left _____ Right _____
- _____ Full side skirts (insulated) (single skin).
- _____ Fascia panels, on _____ side(s) to a _____ high ceiling.
- _____ Grease cup drain. Left _____ Right _____

MECHANICAL REQUIREMENTS

EXHAUST REQUIREMENTS:

- _____ Total CFM required.
- _____ Total exhaust collar(s) @ .75" S.P. each.
- () _____ x _____ Exhaust collar(s) size @ _____ CFM each.

SUPPLY REQUIREMENTS:

- _____ Total CFM required.
- _____ Total supply collar(s) @ .5" S.P. each.
- () _____ x _____ Supply collar(s) size @ _____ CFM each.