



ETL Listed  
File #2001066



## EQUIPMENT SPECIFICATIONS

To be Model EOH wall style exhaust canopy complying with NFPA-96, bearing ETL Sanitation Listing as manufactured by Discount Restaurant Hoods, Inc.

Item to be (L) \_\_\_\_\_ long x (W) \_\_\_\_\_ wide x (D) \_\_\_\_\_ deep in \_\_\_\_\_ section(s) as per drawing. Unit(s) constructed of 18 gauge stainless steel where exposed with external seams and joints welded liquid tight. All exposed surfaces are to be polished to the #4 finish.

Unit(s) to have U.L. classified grease extractors, mounted in stainless steel frame with removable stainless steel grease cup.

3" Air space top and back come standard.

Listed one exhaust duct opening (minimum) for exhaust hoods up to 16 Ft. in length. Listed at minimum 260 CFM per linear foot exhaust.

### Ventilator to have following standard features:

- \_\_\_\_\_ U.L. Listed vapor proof globe type incandescent light fixtures, interwired to junction box.
- \_\_\_\_\_ Aluminum baffle grease extractors.
- \_\_\_\_\_ Grease cup drain. Left \_\_\_\_\_ Right \_\_\_\_\_
- \_\_\_\_\_ Elec. Junction Box, Top. Left \_\_\_\_\_ Right \_\_\_\_\_

### Ventilator to have the following options:

- \_\_\_\_\_ Stainless steel baffle grease extractors.
- \_\_\_\_\_ 110 Volt light switch. Surface mount in stainless steel chase.
- \_\_\_\_\_ 110 Volt fan switch for exhaust and supply.
- \_\_\_\_\_ Mount in stainless steel chase.
- \_\_\_\_\_ 3" side air space. Left \_\_\_\_\_ Right \_\_\_\_\_

## MECHANICAL REQUIREMENTS

### EXHAUST REQUIREMENTS:

- \_\_\_\_\_ Total CFM required.
- \_\_\_\_\_ Total exhaust collar(s) @ .75" S.P. each.
- ( ) \_\_\_\_\_ x \_\_\_\_\_ Exhaust collar(s) size @ \_\_\_\_\_ CFM each.

### SUPPLY REQUIREMENTS:

- \_\_\_\_\_ Total CFM required.
- \_\_\_\_\_ Total supply collar(s) @ .5" S.P. each.
- ( ) \_\_\_\_\_ x \_\_\_\_\_ Supply collar(s) size @ \_\_\_\_\_ CFM each.